

House Type Approval Certificate

Certificate No: **STAS/15/015/DM54/03/AMD02**
Date: **21 March 2017**

A	Certificate Holder:
	Springfield Properties, Springfield House, 3 Central Park Avenue, Larbert, FK5 4RX E-mail: gregor.robertson@springfield.co.uk Tel: 01324 555536

B	House Type Titles:
	Description: 2015 Uplift Melford – 5B 1603CT detached two storey house with integrated garage

C	The domestic type approval has been assessed on the following drawings and specifications:
	See attached annexe to this certificate

D	Climatic conditions: The design may be built in areas where the climatic conditions are equal to or less than those detailed below:		
	Wind: (as defined in BS 6399-2)	Standard effective wind speed, V_e = For maximum effective height = Has funnelling been considered?	44.1 m/s 10.0m NO
	Wind: (as defined in CP3: Chapter V)	Design wind speed, V_s = (relevant to the building frame, at a height of 3m or less)	25.5 m/s
	Snow: (as defined in BS 6399-3)	Site snow load, S_o = Influenced by adjacent buildings?	0.75 Kn/m2 NO
	Resistance to moisture/durability of exposed elements:	Max exposure (to wind driven rain) grading, as defined in BRE Report – Thermal Insulation: Avoiding Risks, Second Edition, 1994, to be exposure zone: Exposure to sea spray (i.e. coastal region) or de-icing salts? Other air contaminants or biological factors – please specify any enhanced resistance if applicable (refer to BS7543 for guidance)	Zone 4 NO
	Design Life: (per BS 7543 – Durability of buildings and building elements, products and components)	Category of building design life = Design life of primary building envelope	60 years 60 years


E	Conditions of certification:
	1. The design shown and the specifications and materials referred to have been assessed and approved in accordance with the Building (Scotland) Regulations 2004 and in accordance with the supporting guidance in the Domestic Technical Handbooks which came into force with effect from 1 October 2015.
	2. The certificate shall be valid until invalidated by formal notice by the Local Authority Building Standards Scotland
	3. The design shown and the materials specified shall not be changed without reference to the Local Authority Building Standards Scotland responsible for certifying the system.
	4. Where reference is made on a plan or specification document to any Code of Practice, British or European Standard or manufacturer's instruction it shall be construed as a reference to such publication in the form in which it is in force at the date of this certificate.
	5. This certificate should not be regarded as a formal approval under the building warrant process prescribed by the Building (Scotland) Act 2003 enacted from 1 May 2005
	6. The Bill Henderson Consulting Engineer Ltd amended statement dated 10 March 2017 referenced here under Section G, confirm that a structural appraisal has been carried out. Further site-specific information MUST BE made available when a site-specific building warrant is sought. Such additional information should take cognisance of Procedural Guidance on Certification including information to be submitted with a Building Warrant Application dated April 2010 Version 2. Confirmation of a holistic approach to structural adequacy of the <u>entire completed building</u> shall be provided by a registered engineer to the local authority within whose area the site specific dwelling is to be built.

Annexe of drawings, certificates and specification documents used in the assessment:

F	Drawing Number:	Description:
	1603dt(AS)103 A	Plot Works Layout, Gas & Air Source Heat Pump Hybrid Heating
	1603dt(AS)306 F	First floor Services Layout
	1603dt(AS)324 C	Ground Floor Services Layout, Gas & Air Source Heat Pump Hybrid Heating
	1603dt(AS)421 A	Elevations, Gas & Air Source Heat Pump Hybrid Heating
	1603dt(AS)701 D	Accessible Cloakroom Layout

G	Certification:	
	BRE Global Ltd Certificate of Design (Section6 – Energy) BRE-S6-1-02535	For all house types
	Amended Statement of structural adequacy	From Bill Henderson Consulting Engineer Ltd dated 10 March 2017

H	Specification:	
	Springfield – 2015 Building Standards Technical Specification Mainstream Housing – Timber Frame, Hybrid Air Source Heat Pump & Gas Central Heating Revision G 21/03/2017	For all house types
	Stroma SAP ratings SAP 2012	For all house types
	Sustainability Bronze Level - 09/03/17	For all house types
	U-value calculation	Floor
	U-value calculation	Exposed floor over garage
	U-value calculation	External Wall
	U-value calculation	Garage Wall
	U-value calculation	Dormer Wall
	U-value calculation	Dwarf Wall
	U-value calculation	Main Roof
	U-value calculation	Slope Roof
	Robust wall specification	Bill Henderson Consulting Engineer Ltd – letter and fixing specification dated 7 March 2017

I	Authority:		
	This system type approval certificate consisting of 2 pages is authorised by:	Signature:	
			Lead Authority Building standards Manager on behalf of the Local Authority Building Standards Scotland (LABSS)

Appendix A

Regulation 9 Provisions on which an alternative approach is given	Decision
Technical Standard 3.12 Sanitary facilities (Domestic)	
Guidance Clause 3.12.3 of the technical handbook for dwellings identifies that walls adjacent to any sanitary facility are of robust construction that will permit secure fixing of grab rails or other aids in the zones noted in figure 3.32	Robust walls to structural engineer's specification (Bill Henderson Consulting Engineer Ltd letter and fixing specification dated 7 March 2017)